

COUNCIL COMMUNICATION

Specifications and Advertisement for Bids for IGENDA TITLE:

Purchase of Battery Capacity Test System (EUD 92-1)

IEETING DATE: January 15, 1992

PREPARED BY: Electric Utility Director

RECOMMENDED ACTION:

That the City Council approve the specifications and

authorize advertisement for bids for the purchase of

Battery Capacity Test System.

BACKGROUND INFORMATION: The Battery Capacity Test System will be used by the

Electrical Systems Group in the maintenance program of the various battery banks utilized for operation and control of power circuit breakers and for uninterruptible

power supplies on computer and SCADA systems. The Test System will determine the condition as well as the ability of these various battery banks to supply the necessary power during an emergency situation or an all-out power failure

The bid opening has been set for Tuesday. February 18, 1392.

Estimated cost of 611.500 is included in the Department's 1991-92 fiscal FUNDING:

year budget.

Henry J. Rfce

Electric Utility Director

Prepared by: Hans Hansen, Assist. Electric Utility Director

Electrical Systems Supervisor cc:

Purchasing Officer

APPROVED Thomas Julison

THOMAS A. PETERSON

City Manager